CERTIFICATE OF COMPLIANCE

Certificate Number 20170516-MH61926
Report Reference MH61926-20170227
Issue Date 2017-MAY-16

Issued to: Precision Dynamics, Inc
402 N. Commerce
Burleson TX 76028

This is to certify that representative samples of Drinking Water Treatment Chemicals
"Aqua Safe Descaler"

Trade Dsg	Category	Max Use Level (mg/L)
"Aqua Safe Descaler" [*OL]	Miscellaneous Treatment Application Products	N/A

[*OL] - These products are designed to be used off-line and flushed out prior to using the system for drinking water, following the manufacturer's use instructions. The pH, phosphate, and other water chemistry of the influent and effluent water should be monitored to ensure that all traces of the product have been removed before placing into service.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: NSF/ANSI 60 (2011),"Drinking Water Treatment Chemicals - Health Effects."

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/